

**LAB CONTROL NUMBER SAMPLE DATE PROCESS DATE EQUIPMENT METER**

**H370-42172-0001** 6/18/12 0.0 HR

No Action Required ALL TESTS APPEAR NORMAL FOR #2 DIESEL FUEL WE RECOMMEND RESAMPLING IF THE FUEL IS NOT USED WITHIN THE NEXT TWELVE MONTHS.

6/20/12

**Al Sb Ba B Ca Cr Cu Fe Pb Mg Mo Ni P K Si Ag Na Sn Ti Zn**

H370-42172-0001 0 0 0 2 3 0 0 0 0 0 0 0 0 0 0 1 8 0 0 1

**W ISO 4μ 6μ 10μ 14μ 18μ 21μ 38μ**

H370-42172-0001 N 19/17/13 4280 1137 162 58 25 15 1

**Wear Metals**

**Fuel Tests**

Notice: This analysis is intended as an aid in predicting mechanical wear. No guarantee, expressed or implied, is made against failure of this piece of equipment or a component thereof.

Particle Count Photo

