

		Outside Temp was 23 degrees						
MBR 3-ton PON (Note: 5-ton unit was also running)								
Water In:	40	Water Out:	37.5	Delta	2.5			
Air Out	76.7	Room Temp	63.5	Delta	13.2	Stage 1	taken at unit	
	89		65		24	Stage 2	taken at registers	
5-Ton POND								
Water In:	41.5	Water Out:	39	Delta	2.5			
Air Out	84.8	Room Temp	69.3	Delta	15.5	Stage 1	taken at unit	
	89.1		67.1		22	Stage 2	taken at unit	
3-ton GROUND								
Water In:	56	Water Out:	53	Delta	3			
Air Out	90	Room Temp	68.7	Delta	21.3	Stage 1	taken at unit	
	96		68		28	Stage 2	taken at registers	